

Section 10

Steam System Optimization - Cogeneration


Backpressure Turbine – PRV Operations

SSAT Turbine Projects Economics

Condensing Turbine Impacts

SSAT Condensing Turbine Projects

Industrial Cogeneration



Industrial facilities can achieve “overall energy efficiency” of 70% or higher, because they have a need for thermal energy (heat).....

Classic Cogeneration Analysis

- ✓ The classic cogeneration analysis answers the following questions:
- What is the true economic impact of cogeneration?
 - When is it viable?
 - To operate or shut down
 - To install
 - What changes, if any, will be required on the steam system?
 - What changes, if any, will be required for the electrical utility system and grid interconnects?

Primary Factors for Cogeneration Analysis


- ✓ The primary factors impacting the analysis are:
- Impact electrical cost
 - Impact fuel cost
 - Boiler efficiency
 - Steam turbine efficiency
 - Steam demand

Impact Costs


- ✓ Impact cost is the actual economic impact of increasing or decreasing electrical consumption
- ✓ The average cost of electricity is typically NOT the appropriate analysis value
- ✓ A thorough understanding of the electric rate structure is essential to evaluate the true impact of power generation systems

Example Turbine-PRV Evaluation


- ✓ A process unit is equipped with 6 identical pumps that are installed in parallel
 - Only 3 of the 6 pumps are required to operate continuously
 - The remaining pumps are spare (backup) units
 - Electric motors drive 4 of the pumps and steam turbines drive 2 of the pumps
 - 1 turbine-drive is being used at this time
- ✓ Identify the economic incentive associated with operating the second turbine
 - Compared to operating an electric motor driven pump and passing steam through a Pressure reducing Valve (PRV) to satisfy the low pressure demands



Steam System



Turbine-PRV Economics



PRV Operations

$$h_{steam} = 3,180.9 \frac{kJ}{kg} \quad \text{P} = 25 \text{ bars; T} = 375^{\circ}\text{C}$$

$$h_{PRVout} = 3,180.9 \frac{kJ}{kg} \quad \text{P} = 2 \text{ bars; Isenthalpic; T} = 354.7^{\circ}\text{C}$$


$$h_{condensate} = 562.2 \frac{kJ}{kg} \quad \text{P} = 2 \text{ bars; Saturated Condensate; T} = 133.7^{\circ}\text{C}$$

$$Q_{thermal} = 14,300 \text{ kW}$$

$$Q_{thermal} = m_{PRV} \times (h_{PRVout} - h_{condensate})$$

$$m_{PRV} = \frac{14,300}{(3,180.9 - 562.2)} = 5.45 \frac{kg}{s} = 19.63 \text{ Tph}$$

PRV Operations



Backpressure Turbine Economics

- ✓ Most industrial systems require thermal energy (not mass flow of steam)
- ✓ The turbine will extract energy from the steam and convert it into shaft energy
 - The steam will exit the turbine with a reduced temperature
- ✓ The result will be an increased mass flow of steam required to satisfy the thermal demand

Steam Turbine Operations

$$h_{steam} = 3,180.9 \frac{kJ}{kg} \quad \text{P} = 25 \text{ bars; T} = 375^{\circ}\text{C}$$

$$h_{Turbineout} = 3,009.8 \frac{kJ}{kg} \quad \text{P} = 2 \text{ bars; T} = 271^{\circ}\text{C}$$


$$h_{condensate} = 562.2 \frac{kJ}{kg} \quad \text{P} = 2 \text{ bars; Saturated Condensate; T} = 133.7^{\circ}\text{C}$$

$$Q_{thermal} = 14,300 \text{ kW}$$

$$Q_{thermal} = m_{turbine} \times (h_{Turbineout} - h_{condensate})$$

$$m_{PRV} = \frac{14,300}{(3,009.8 - 562.2)} = 5.83 \frac{kg}{s} = 21.0 \text{ Tph}$$

Steam Turbine Operation



PRV - Backpressure Turbine Economics

✓ Electrical Energy and Cost Savings

$$\text{Energy Savings} = 1,000 \times 8,760 = 8,760 \text{ MWh}$$

$$\text{Energy Cost Savings} = 8,760 \times 1,000 \times 0.14 = \$1,226,400$$

✓ Fuel Energy and Cost Increase

$$\text{Energy Increase} = (m_{\text{Turbine}} - m_{\text{PRV}}) \times 1,000 \times \frac{(h_{\text{steam}} - h_{\text{feedwater}})}{\eta_{\text{boiler}}} \times 8,760$$

$$\text{Energy Increase} = (21 - 19.6) \times 1,000 \times \frac{(3180.9 - 463.5)}{0.80} \times 8,760 = 41,658 \text{ GJ}$$

$$\text{Energy Cost Increase} = \frac{41,658 \times 1,000 \times 1000}{40,144} \times 0.52 = \$539,600$$

PRV - Backpressure Turbine Economics

✓ Net Economic Impact

Electric Power Cost Savings = \$1,226,400

Fuel Cost Increase = \$539,600

Net Economic Benefit = \$686,800

✓ The primary factors impacting the analysis are:

- Impact electrical cost
- Impact fuel cost
- Boiler efficiency
- Steam turbine efficiency
- Steam demand

PRV - Backpressure Turbine Economics

✓ Net Economic Impact

Electric Power Cost Savings = \$1,226,400

Fuel Cost Increase = \$539,600

Net Economic Benefit = \$686,800

- ✓ This identical analysis can be and should be done with SSAT Projects 7, 8 and 9 depending on which turbine is being modeled in the analysis
 - Systems approach versus Component-based approach

SSAT Project 7 – HP-LP Steam Turbine

Project 7 - HP to LP Steam Turbine(s)

Efficiency : 35% Operation : Operates with fixed steam flow

Do you wish to modify the HP to LP turbine operation?

No

If yes, select the appropriate turbine operating mode

Option 2 - Fixed operation

Note: If Option 1 is chosen, the model will preferentially use the HP to LP turbine to balance the LP demand

Specify a new isentropic efficiency (%)

35 %

Note: A generator electrical efficiency of 100% is assumed by the model

Note: Isentropic efficiency of existing turbine is 35%

Option 2 - How do wish to define the fixed turbine operation?

Specify fixed steam flow

Option 2 - Fixed steam flow

42 t/h

Option 2 - Fixed power generation

2000 kW

Option 3 - How do wish to define the operating range?

Option 3 not selected

Option 3 - Minimum steam flow

25 t/h

Option 3 - Maximum steam flow

75 t/h

Option 3 - Minimum power generation

1500 kW

Option 3 - Maximum power generation

2500 kW

SSAT Project 8 – HP-MP Steam Turbine

Project 8 - HP to MP Steam Turbine(s) Not installed

Do you wish to add an HP to MP turbine?

No



If yes, select the appropriate turbine operating mode

Option 1 - Balances MP header



Specify a new isentropic efficiency (%)

70 %

Note: A generator electrical efficiency of 100% is assumed by the model

Option 2 - How do wish to define the fixed turbine operation?

Option 2 not selected



Option 2 - Fixed steam flow

50 t/h

Option 2 - Fixed power generation

2000 kW

Option 3 - How do wish to define the operating range?

Option 3 not selected



Option 3 - Minimum steam flow

25 t/h

Option 3 - Maximum steam flow

75 t/h

Option 3 - Minimum power generation

1500 kW

Option 3 - Maximum power generation

2500 kW

SSAT Project 9 – MP-LP Steam Turbine

Project 8 - HP to MP Steam Turbine(s) Not installed

Do you wish to add an HP to MP turbine?

No



If yes, select the appropriate turbine operating mode

Option 1 - Balances MP header



Specify a new isentropic efficiency (%)

70 %

Note: A generator electrical efficiency of 100% is assumed by the model

Option 2 - How do wish to define the fixed turbine operation?

Option 2 not selected



Option 2 - Fixed steam flow

50 t/h

Option 2 - Fixed power generation

2000 kW

Option 3 - How do wish to define the operating range?

Option 3 not selected



Option 3 - Minimum steam flow

25 t/h

Option 3 - Maximum steam flow

75 t/h


Option 3 - Minimum power generation

1500 kW

Option 3 - Maximum power generation

2500 kW

SSAT Analysis – HP-LP Steam Turbine



SSAT - Shaft Power
(Generator Efficiency = 100%)

SSAT Project 7 – HP-LP Steam Turbine

Project 7 - HP to LP Steam Turbine(s)

Efficiency : 35% Operation : Operates with fixed steam flow

Do you wish to modify the HP to LP turbine operation?

Yes, modify operation of existing turbine



If yes, select the appropriate turbine operating mode

Option 2 - Fixed operation



Note: If Option 1 is chosen, the model will preferentially use the HP to LP turbine to balance the LP demand

Specify a new isentropic efficiency (%)

35 %

Note: A generator electrical efficiency of 100% is assumed by the model

Note: Isentropic efficiency of existing turbine is 35%

Option 2 - How do wish to define the fixed turbine operation?

Specify fixed steam flow



Option 2 - Fixed steam flow

42 t/h

Option 2 - Fixed power generation

2000 kW

Option 3 - How do wish to define the operating range?

Option 3 not selected



Option 3 - Minimum steam flow

25 t/h

Option 3 - Maximum steam flow

75 t/h


Option 3 - Minimum power generation

1500 kW

Option 3 - Maximum power generation

2500 kW

SSAT Project 7 – HP-LP Steam Turbine



SSAT - Shaft Power
(Gen Efficiency = 100%)

SSAT Project 7 – HP-LP Steam Turbine

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	4,911	1,221	19.9%
Fuel Cost	57,501	58,067	-566	-1.0%
Make-Up Water Cost	1,086	1,095	-10	-0.9%
Total Cost (in \$ '000s/yr)	64,718	64,073	645	1.0%

On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	221739 t/yr	223924 t/yr	-2184 t/yr	-1.0%
SOx Emissions	0 t/yr	0 t/yr	0 t/yr	N/A
NOx Emissions	439 t/yr	443 t/yr	-4 t/yr	-1.0%

Power Station Emissions	Reduction After Projects		Total Reduction	
CO2 Emissions	6213 t/yr		4029 t/yr	-
SOx Emissions	19 t/yr		19 t/yr	-
NOx Emissions	14 t/yr		10 t/yr	-

Note - Calculates the impact of the change in site power import on emissions from an external power station. Total reduction values are for site + power station

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	2996 kW	-	-
Power Import	5000 kW	4004 kW	996 kW	19.9%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	142150 kW	-1387 kW	-1.0%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12747.5 Nm3/h	-124.4 Nm3/h	-1.0%
Boiler Steam Flow	150.1 t/h	151.6 t/h	-1.5 t/h	-1.0%
Fuel Cost (in \$/MWh)	46.63	46.63	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m3/h	74 m3/h	-1 m3/h	-0.9%

SSAT Project 7 – HP-LP Steam Turbine

- ✓ Differences between the “Manual” versus “Model” calculated results can be significant when working with cogeneration type projects
- ✓ The Model results are very accurate
 - Uses a SYSTEM approach and not just a component
 - Impact of condensate temperature
 - Impact of blowdown, deaerator steam flow, make-up water, etc.
 - Completes a detailed mass, energy and economic balance
- ✓ ALWAYS use a SYSTEM based model for analysis

Electrical Price Impact

- ✓ Electrical price is increased from 0.14 \$/kWh to 0.15 \$/kWh

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,570	5,261	1,309	19.9%
Fuel Cost	57,501	58,067	-566	-1.0%
Make-Up Water Cost	1,086	1,095	-10	-0.9%
Total Cost (in \$ '000s/yr)	65,156	64,424	733	1.1%

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	2996 kW	-	-
Power Import	5000 kW	4004 kW	996 kW	19.9%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	142150 kW	-1387 kW	-1.0%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12747.5 Nm3/h	-124.4 Nm3/h	-1.0%
Boiler Steam Flow	150.1 t/h	151.6 t/h	-1.5 t/h	-1.0%
Fuel Cost (in \$/MWh)	46.63	46.63	-	-
Power Cost (as \$/MWh)	120.00	120.00	-	-
Make-Up Water Flow	73 m3/h	74 m3/h	-1 m3/h	-0.9%

Fuel Price Impact

- ✓ Fuel price is increased from \$0.52 to \$1.2 per Nm³ (\$12.8 to 29.5 per GJ)

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	4,911	1,221	19.9%
Fuel Cost	132,694	134,001	-1,307	-1.0%
Make-Up Water Cost	1,086	1,095	-10	-0.9%
Total Cost (in \$ '000s/yr)	139,912	140,007	-95	-0.1%

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	2996 kW	-	-
Power Import	5000 kW	4004 kW	996 kW	19.9%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	142150 kW	-1387 kW	-1.0%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm ³ /h	12747.5 Nm ³ /h	-124.4 Nm ³ /h	-1.0%
Boiler Steam Flow	150.1 t/h	151.6 t/h	-1.5 t/h	-1.0%
Fuel Cost (in \$/MWh)	67.26	67.26	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m ³ /h	74 m ³ /h	-1 m ³ /h	-0.9%

Fuel Impact

- ✓ Impact fuel is now coal at a price of \$250 per tonne instead of Natural gas at \$0.52 per Nm³; (\$7.8 per GJ instead of \$12.8 per GJ)
- ✓ Boiler efficiency for coal is 86.7% versus 81.7% for Natural gas

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	4,911	1,221	19.9%
Fuel Cost	32,793	33,116	-323	-1.0%
Make-Up Water Cost	1,086	1,095	-10	-0.9%
Total Cost (in \$ '000s/yr)	40,011	39,122	889	2.2%


On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	360804 t/yr	364359 t/yr	-3554 t/yr	-1.0%
SOx Emissions	2621 t/yr	2647 t/yr	-26 t/yr	-1.0%
NOx Emissions	1007 t/yr	1017 t/yr	-10 t/yr	-1.0%

Power Station Emissions	Reduction After Projects	Total Reduction	
CO2 Emissions	6213 t/yr	2659 t/yr	-
SOx Emissions	19 t/yr	-7 t/yr	-
NOx Emissions	14 t/yr	4 t/yr	-

Note - Calculates the impact of the change in site power import on emissions from an external power station. Total reduction values are for site + power station

Improved Turbine Efficiency

✓ The isentropic turbine efficiency is now 65% instead of 35%




Power produced is < 2,000 kW

✓ Higher efficiency turbine extracts more power out of the steam thereby reducing steam enthalpy at the exhaust

- Resulting in more steam to be generated by the boilers!

Improved Turbine Efficiency

✓ The isentropic turbine efficiency is now 65% instead of 35%



Power produced is >3000 kW

✓ Higher efficiency turbine extracts more power out of the steam thereby reducing steam enthalpy at the exhaust

- Resulting in more steam to be generated by the boilers!

Improved Turbine Efficiency

- ✓ The isentropic turbine efficiency is now 65% instead of 35%

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	2,813	3,319	54.1%
Fuel Cost	57,501	59,040	-1,539	-2.7%
Make-Up Water Cost	1,086	1,112	-26	-2.4%
Total Cost (in \$ '000s/yr)	64,718	62,964	1,754	2.7%

On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	221739 t/yr	227674 t/yr	-5935 t/yr	-2.7%
SOx Emissions	0 t/yr	0 t/yr	0 t/yr	N/A
NOx Emissions	439 t/yr	451 t/yr	-12 t/yr	-2.7%

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	4706 kW	-	-
Power Import	5000 kW	2293 kW	2707 kW	54.1%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	144531 kW	-3768 kW	-2.7%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12961 Nm3/h	-337.9 Nm3/h	-2.7%
Boiler Steam Flow	150.1 t/h	154.1 t/h	-4.0 t/h	-2.7%
Fuel Cost (in \$/MWh)	46.63	46.63	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m3/h	75 m3/h	-2 m3/h	-2.4%


Turbine-PRV Examples Summary Information

- ✓ These examples indicate the critical importance of impact parameter accuracy

Power Cost	Fuel cost	Turbine Efficiency	Boiler Eff. SSAT	Addl. Power	Addl. Steam	Cost Savings
(\$/kWh)	(\$/GJ)	(%)	(%)	(kW)	(T/hr)	(\$/Yr)
0.14	12.8	35	81.7	996	1.5	645,000
0.15	12.8	35	81.7	996	1.5	733,000
0.14	29.5	35	81.7	996	1.5	-95,000
0.14	7.8	35	86.7	996	1.5	889,000
0.14	12.8	65	81.7	2707	4.0	1,754,000

- ✓ It is VERY IMPORTANT to conduct this analysis for each facility
 - Each facility is unique and will need significant due diligence before implementation of these projects

Backpressure Turbine Economics



Variables for Industrial Applications

- ✓ Constant steam flow
- ✓ High pressure supply steam
- ✓ Existing Pressure Reducing Valve (PRV)
- ✓ Multiple steam header system
- ✓ Simultaneous steam and electric (power) demand
- ✓ High run hours




Key Points / Action Items

1. *Backpressure turbines are used instead of pressure letdown stations*
2. *Turbine efficiency is NOT 1st law efficiency but a comparison of actual turbine versus an ideal turbine*
3. *Continuous operations with a simultaneous thermal and electric demand are good candidates for backpressure turbines*
4. *Each facility analysis is unique and will depend on several economic as well as operating factors*
5. *Turbine analysis will need a solid thermodynamic steam system model*




- ✓ Condensing turbine discharge steam pressure is less than atmospheric pressure
 - The steam must be condensed to pump it back into the boiler
 - Exiting steam quality is typically much greater than 90%

Condensing Steam Turbines



Source: US DOE ITP Steam BestPractices Program


Condensing Steam Turbines



- ✓ The steam entering the condenser contains a huge amount of fuel energy

Source: US DOE ITP Steam BestPractices Program

Condensing Steam Turbines



✓ The primary factors influencing condensing turbine operations are:

- Purchased power cost
- Purchased fuel cost
- Turbine efficiency
- Boiler efficiency
- Turbine discharge pressure


✓ Efficiency reductions can result from:

- Blade deposits
- Blade erosion
- Seal wear
- Wet steam
- Throttling

✓ Efficiency improvements can result from

- Replaced blades
- Improved seals
- Turbine replacement
- Increased load


Condensing Steam Turbines




Source: US DOE ITP Steam BestPractices Program

Condensing Steam Turbines

- ✓ Condenser pressure can be reduced (improved) by
- Removing non-condensable gases from condenser
 - Cleaning the condenser
 - Supplying the condenser with reduced temperature water
 - Supplying the condenser with additional cooling water



Source: US DOE ITP Steam BestPractices Program



Steam System

SSAT Project 10 – Condensing Steam Turbines

Project 10 - HP to Condensing Steam Turbine(s)

Efficiency : 65% Operation : Operates at fixed power generation

Do you wish to modify the HP to condensing turbine operation?

No, maintain current operation

If yes, enter a new isentropic efficiency (%)

70 %

Note: A generator electrical efficiency of 100% is assumed by the model

Note: Isentropic efficiency of existing turbine is 65%

If yes, select the units to specify the condenser pressure

bara

New condenser pressure (bara)

0.15

Note: Existing condenser pressure is 0.15 bara

If yes, select the new mode of operation

Option 1 - Fixed power generation

Option 1 - Fixed power generation

1000 kW

Option 2 - Fixed steam flow

25 t/h


✓ Implementing SSAT Project 10 will involve a major change in steam demand

- Be very careful while evaluating this project


SSAT Project 10 - Condensing Steam Turbines

✓ SSAT allows

- The addition of a condensing turbine
- Modification of major aspects of an existing turbine
 - Isentropic efficiency
 - Discharge pressure
 - Load
 - Flow
 - Power
- Elimination of the operation of a turbine



SSAT Project 10 - Condensing Steam Turbines



SSAT Project 10 - Condensing Steam Turbines

Project 10 - HP to Condensing Steam Turbine(s)

Efficiency : 65% Operation : Operates at fixed power generation

Do you wish to modify the HP to condensing turbine operation?

Yes, switch off existing turbine



If yes, enter a new isentropic efficiency (%)

70 %

Note: A generator electrical efficiency of 100% is assumed by the model

Note: Isentropic efficiency of existing turbine is 65%

If yes, select the units to specify the condenser pressure

bara



New condenser pressure (bara)

0.15

Note: Existing condenser pressure is 0.15 bara

If yes, select the new mode of operation

Not installed



Option 1 - Fixed power generation


1000 kW

Option 2 - Fixed steam flow

25 t/h

✓ Impact of switching off the condensing turbine

SSAT Project 10 - Condensing Steam Turbines



SSAT Project 10 - Condensing Steam Turbines

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 8

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	4,039	2,093	34.1%
Fuel Cost	57,501	56,586	915	1.6%
Make-Up Water Cost	1,086	1,107	-21	-2.0%
Total Cost (in \$ '000s/yr)	64,718	61,732	2,986	4.6%

On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	221740 t/yr	218212 t/yr	3527 t/yr	1.6%
SOx Emissions	0 t/yr	0 t/yr	0 t/yr	N/A
NOx Emissions	439 t/yr	432 t/yr	7 t/yr	1.6%

Power Station Emissions	Reduction After Projects		Total Reduction	
CO2 Emissions	10645 t/yr		14172 t/yr	-
SOx Emissions	33 t/yr		33 t/yr	-
NOx Emissions	24 t/yr		31 t/yr	-

Note - Calculates the impact of the change in site power import on emissions from an external power station. Total reduction values are for site + power station

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	3706 kW	-	-
Power Import	5000 kW	3294 kW	1706 kW	34.1%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	138524 kW	2239 kW	1.6%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12422.3 Nm3/h	200.8 Nm3/h	1.6%
Boiler Steam Flow	150.1 t/h	147.7 t/h	2.4 t/h	1.6%
Fuel Cost (in \$/MWh)	46.63	46.63	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m3/h	74 m3/h	-1 m3/h	-2.0%


Condensing Turbine Performance


Condensing Turbine Impact Power Cost			
Turbine Eff. (%) >	40	60	80
Fuel Cost [\$ / GJ]	Condensing Power Cost [\$ / MWh]		
2.0	56	39	30
4.0	111	78	60
6.0	167	116	89
8.0	223	155	119
10.0	278	194	149
12.0	334	233	179
Steam inlet	25	bars	
Steam inlet	375	°C	
Steam exit	0.1	bar(a)	

Condensing Turbine Pressure Effect

- ✓ It should be noted that a minimum pressure is generally attained where maximum energy utilization efficiency is achieved
 - In other words, there is generally a pressure threshold that further reductions in discharge pressure result in reducing overall cost effectiveness
 - Velocity losses begin to be excessive
 - This is very dependent on the turbine design
 - Larger annular steam flow area reduces the loss
 - Condensate is returned to the boiler at lower temperature
 - Common design is for 1.5 inches of mercury absolute (0.74 psia) condenser pressure

Condensing Turbine Pressure Effect





Key Points / Action Items

1. *Condensing turbines are used strictly for power generation or driving large mechanical equipment*
2. *They serve niche applications in the industry*
3. *Condensing turbines provide maximum shaft power per unit of steam flow*
4. *Each facility analysis is unique and will depend on several economic as well as operating factors*
5. *Turbine analysis will need a solid thermodynamic steam system model*



Common BestPractices –Turbines

- ✓ Process and utility integration leads to overall energy optimization of the plant
- ✓ Install backpressure turbines in parallel with pressure letdown stations and minimize flow through letdown stations
- ✓ Evaluate backpressure turbine applications for direct mechanical drives
- ✓ Evaluate condensing turbines and optimize their operations to maintain design conditions
- ✓ Condensing turbines can serve as a system balance mechanism especially, in industries which have significant waste heat steam generation