

Section 9

Steam System Optimization Condensate Recovery

Types of Steam Traps

Steam Trap Management Program

SSAT Evaluations & Economic Impacts


Evaluation of Condensate Recovery Systems

Condensate Flash Tanks

Condensate Tank Vents

SSAT Evaluations & Economic Impacts

Generic Steam System



Source: US DOE ITP Steam BestPractices Program

Steam Traps

- ✓ Traps serve several vital operating functions for a steam system
 - During start-up, they allow air and large quantities of condensate to escape
 - During normal operation, they allow collected condensate to pass into the condensate return system, while minimizing (or eliminating) loss of steam
- ✓ There are different kinds of steam traps and hence, functionality and principles of operation must be understood
- ✓ All plants should have an effective steam trap management program
- ✓ Steam trap failures may not result in energy loss per se, but they will surely result in system operation problems and reliability issues

Types of Steam Traps

✓ Thermostatic Traps

- Bellows*
- Bimetallic*

✓ Mechanical Traps

- Ball Float
- Float and Lever
- Inverted Bucket*
- Open Bucket
- Float and Thermostatic*

✓ Thermodynamic Traps



- Disc*
- Piston
- Lever

✓ Orifice Traps

- Orifice Plate
- Venturi Tube

* - Most commonly used


Thermostatic Steam Traps



- ✓ Responds to temperature changes
- ✓ A bellows (with a volatile fluid) or a bimetallic strip closes the valve with high temperature steam
- ✓ When condensate (typically, sub-cooled) collects – the bellows contracts and opens the valve to let condensate drain out


Thermostatic Steam Traps

- ✓ Opens to subcooled condensate
- ✓ Depending on subcooling can discharge condensate or condensate and flash steam
- ✓ Allows energy recovery from condensate
- ✓ Significant air removal capability



Source: US DOE ITP Steam BestPractices Program

Mechanical Steam Traps





- ✓ Opens to saturated and/or sub-cooled condensate
- ✓ Will discharge condensate and flash steam
- ✓ Significant air removal and startup capabilities
- ✓ Modulating type operation

Float & Thermostatic Trap (F&T)

Source: US DOE ITP Steam BestPractices Program

Mechanical Steam Traps





**Inverted Bucket Trap
(Open Float)**

- ✓ Opens to saturated and/or sub-cooled condensate
- ✓ Will discharge condensate and flash steam
- ✓ Limited air removal and startup capabilities
- ✓ Application in superheated steam service should be questioned
- ✓ Intermittent operation

Source: US DOE ITP Steam BestPractices Program

Thermodynamic Steam Traps




Disc Trap

- ✓ Works on the difference in kinetic energy (velocity) between condensate and steam to operate a valve
- ✓ Opens to saturated condensate
- ✓ Will discharge condensate and flash steam
- ✓ Intermittent operation
- ✓ Can be equipped with thermostatic element to improve air removal

Source: US DOE ITP Steam BestPractices Program




Orifice Steam Traps










- ✓ Its designed for a specific amount of condensate removal
- ✓ If there is no condensate, then a small amount of steam leaks continuously
- ✓ No moving parts
- ✓ Continuous operation
- ✓ Common applications are steady loads
- ✓ Limited air removal capability due to orifice limitations

Source: US DOE ITP Steam BestPractices Program

Steam Traps in the Field



Steam Traps in the Field



Steam Trap Failures

- ✓ There have been numerous studies in the industry and one of the more statistically accepted “rule of thumb” is that 10% of traps fail every year
- ✓ This depends on several factors and can be very industry specific also
- ✓ The main failure modes are:
 - Failed closed
 - Failed open
 - Failed partially leaking or partially closed
- ✓ Failed open and failed closed result in the greatest system impacts
 - These failure modes are the most readily recognized
 - These failures should be of first priority

Steam Trap Investigation for Performance

- ✓ There are several methods for investigating steam trap performance
 - Visual
 - Acoustic
 - Thermal
- ✓ Most times, using only one method maybe inconclusive – so the following is recommended
 - Combination of methods
 - Additional process or system information, is required
- ✓ New state-of-the-art in-trap (real-time) monitoring is available for some steam traps

Visual Steam Trap Investigation

- ✓ Limited in applicability
 - Most condensate systems are closed
 - Safety and practicality limit the use of this method
- ✓ Individual trap operation and application must be understood
 - Intermittent
 - Continuous
- ✓ Several traps can return condensate via a cascaded condensate return system – condensate receiver vent becomes the point of visual inspection

Acoustic Steam Trap Investigation


- ✓ Many instruments are available
 - Screw driver
 - Stethoscope
 - Ultrasonic devices
- ✓ Individual trap operation and application must be understood
- ✓ Ultrasonic sensing is typically the most practical
- ✓ Some manufacturers have tools that can take the acoustic signature of steam flow through the trap and use that information to detect failure

Thermal Steam Trap Investigation

- ✓ Many instruments are available
 - Temperature stick
 - Infra-red temperature gun
 - Infra-red thermography camera
- ✓ Individual trap operation and application must be understood
- ✓ Data can be inconclusive
 - Condensate and steam will take a temperature drop while going through an orifice – hence, difficult to say if trap is failed open!

Steam Trap Survey - Condensate Recovery Investigation

- ✓ Is condensate being recovered?
- ✓ Is the condensate recovered to the boilers with the greatest practical thermal energy?
- ✓ Does the condensate recovery system place excessive backpressure on the traps?
- ✓ Is flash steam recovery applicable?
- ✓ Design the condensate recovery system for the greatest effectiveness



Source: US DOE ITP Steam BestPractices Program

Steam Trap Installation

- ✓ Each trap must be installed properly
- ✓ Non-condensable gas and startup considerations must be targeted
- ✓ The condensate collection system must be considered
 - Backpressure considerations
 - Lift considerations
 - Two-phase flow considerations

Effective Steam Trap Management Program

- ✓ Maintain a steam trap database
 - Type of trap, model number, size, etc
 - Application
 - Energy loss if failed open
 - Problems if failed closed
 - When was the last recorded failure, repair
- ✓ Prioritize repairs based on loss estimates and criticality of steam system and production operations
- ✓ Daily monitor receiver vents
- ✓ Inspect all traps at least once a year
- ✓ Trap maintenance training is essential

Steam Trap Savings Analysis

✓ 1st method

- Use SSAT to predict savings – preliminary estimate
- Number of traps & last maintenance done

✓ 2nd method

- Use SSAT to provide savings
- Number of failed traps

✓ 3rd method

- Use orifice size and calculate steam leak flow
- Use SSAT – Project 1 as demand savings
- Most accurate method – especially for cogeneration systems

SSAT Project 16 - Savings Analysis

✓ 1st method (Option 1)

- Use SSAT to predict savings – preliminary estimate
- Number of traps & last maintenance done
- Very GROSS Estimate

Project 16 - Steam Trap Losses

Losses calculated from user-defined data

Do you wish to model the impact of a maintenance program?

Option 1 - Yes, model to estimate new loss values



Note: For Option 1, the model estimates a new trap failure rate. The rate reported is for 6 months after the maintenance program is carried out

Option 2 - Trap failures on HP header

5

Failures > Current - Model will use 0

Option 2 - Trap failures on MP header

5

Failures > Current - Model will use 0

Option 2 - Trap failures on LP header

5

Failures > Current - Model will use 0

Note: Calculated values based on current user inputs are:-

HP header - Trap failures: 0, Loss per trap 0.034 t/h - Total trap loss = 0.00 t/h.

MP header - Trap failures: 0, Loss per trap 0.014 t/h - Total trap loss = 0.00 t/h.

LP header - Trap failures: 0, Loss per trap 0.003 t/h - Total trap loss = 0.00 t/h.

SSAT Project 16 - Savings Analysis

- ✓ 2nd method (Option 2)
 - Use SSAT to provide savings
 - Number of failed traps
 - A GROSS estimate

Project 16 - Steam Trap Losses

Losses estimated automatically by model - Last maintenance program 3-5 years ago

Do you wish to model the impact of a maintenance program?

Option 2 - Yes, enter new number of failed traps



Note: For Option 1, the model estimates a new trap failure rate. The rate reported is for 6 months after the maintenance program is carried out

→	Option 2 - Trap failures on HP header	5		←
→	Option 2 - Trap failures on MP header	5		←
→	Option 2 - Trap failures on LP header	5		←

Note: Calculated values based on current user inputs are:-

HP header - Trap failures: 5, Loss per trap 0.034 t/h - Total trap loss = 0.17 t/h.

MP header - Trap failures: 5, Loss per trap 0.014 t/h - Total trap loss = 0.07 t/h.

LP header - Trap failures: 5, Loss per trap 0.003 t/h - Total trap loss = 0.02 t/h.

SSAT Project 1 - Steam Trap Savings Analysis

- ✓ 3rd Method – most accurate
- ✓ Work with open failed steam traps and prepare a list of traps failed at each pressure level

$$m_{steam} = 0.695 \times A_{orifice} \times P_{steam}$$

Project 1 - Steam Demand Savings (Changing the process steam requirements)

Current use - HP: 20 t/h (12273 kW) MP: 40 t/h (26660 kW) LP: 76 t/h (54448 kW)

Do you wish to specify steam demand savings?

Yes




If yes, enter HP steam saving	0 t/h	
If yes, enter MP steam saving	0 t/h	
If yes, enter LP steam saving	0 t/h	

Note: A negative saving can be entered to model an increase in steam demand

Note: The savings have been converted to heat duties of 0 kW (HP), 0 kW (MP) and 0 kW (LP) based on current header enthalpies

Note: These heat duties are then used to determine the actual flow change in the Projects Model based on the calculated header enthalpies



Key Points / Action Items

1. *There are different kinds of steam traps and hence, functionality and principles of operation must be understood*
2. *Major steam trap failure modes - open / closed*
3. *An effective steam trap management program must be in place*
4. *There are several commercially available tools for steam trap investigations*
5. *Conduct a steam trap audit at least once a year and repair/replace defective traps*
6. *Steam trap manufacturers are a valuable resource*



Condensate Recovery

- ✓ Condensate is produced after steam has transferred all its thermal energy and condensed into water
- ✓ Nevertheless, there is significant thermal energy in condensate
- ✓ Every unit of condensate returned implies one less unit of make-up required
- ✓ Returning condensate
 - Reduces energy (steam required) in deaerator
 - Reduces make-up water
 - Reduces chemicals for water treatment
 - Reduces quenching water
 - May reduce blowdown

Condensate Recovery


- ✓ Condensate typically has worth
 - Energy
 - Make-up water reduction
 - This generally improves feedwater quality
 - Resulting in a reduction in boiler blowdown
 - Chemical
- ✓ Condensate recovery costs generally center on the recovery system piping
 - Recovery equipment
 - Return piping

Condensate Recovery

- ✓ Condensate receivers serving “areas” can reduce project costs
- ✓ Condensate receivers and flash tanks serve to reduce the amount of steam entering the condensate return piping reducing flow restriction problems
- ✓ Contaminated condensate is a critical issue
- ✓ Receiver vents are indicative of trap failures
- ✓ Pump NPSH issues must be investigated


Source: US DOE ITP Steam BestPractices Program

Condensate Return Example



Measured condensate temperature 100°C.
Condensate flow measured by bucket and stopwatch (mass and energy balance is also a common method) to be 50 litres/minute

Condensate Return Example



Source: US DOE ITP Steam BestPractices Program

Condensate Return Example

- ✓ Enthalpy of condensate: 293.1 kJ/kg
 - ✓ Enthalpy of make-up: 83.9 kJ/kg
 - ✓ Condensate flow rate: 50 litres/min
- } From Steam Tables

$$m_{\text{condensate}} = 50 \times 977.8 \times \frac{1}{1000} \times \frac{1}{60} = 0.81 \frac{\text{kg}}{\text{s}}$$

$$Q_{\text{condensate}} = m_{\text{condensate}} \times (h_{\text{condensate}} - h_{\text{makeup}})$$

$$Q_{\text{condensate}} = 0.81 \times (293.1 - 83.9) = 169.5 \text{ kW}$$


$$Q_{\text{system}} = Q_{\text{condensate}} \times \frac{1}{\eta_{\text{boiler}}} = 169.5 \times \frac{1}{0.80} = 212 \text{ kW}$$

$$\text{Energy Savings} = 212 \times 3,600 \times \frac{1}{40,144} \times 0.52 \times 8,760 \approx \$87,000$$

SSAT Project 13 - Condensate Return Savings

Process Condensate	Input Data	Warnings
Condensate return temperature to tank	70 °C	
HP condensate recovery	50 %	
MP condensate recovery	50 %	
LP condensate recovery	50 %	

Note: Condensate recovery specified as the percentage of steam supplied to the processes at each level



SSAT Project 13 – Condensate Return Savings

- ✓ Note that SSAT requires condensate return input as a percent of steam supplied to the process at each header level
 - Manual calculations will be needed to get to the new value of condensate returned
 - Steam demand on LP = 76 Tph
 - Current condensate returned = 50%
 - Current condensate returned = 35 Tph
 - Additional condensate = $0.81 \text{ kg/s} = 2.92 \text{ Tph}$
 - New condensate return = $35 + 2.92 = 37.92 \text{ Tph}$
 - New condensate return = $37.92 / 70 = 54.17\%$

SSAT Project 13 – Condensate Return Savings

Project 13 - Condensate Recovery

Currently recover 50% of HP, 50% of MP and 50% of LP at 70°C

Do you wish to specify new condensate recovery rates?

Yes




→ If yes, enter new HP condensate recovery	50 %		←
→ If yes, enter new MP condensate recovery	50 %		←
→ If yes, enter new LP condensate recovery	54.17 %		←

Note: Condensate return temperature will be assumed to be 70°C as for the current operation

- ✓ Note that SSAT needs information of condensate recovery on all the headers even though the project being modeled is only on one of the headers
 - Other headers should have the same numbers as the “Input” page

SSAT Project 13 – Condensate Return Savings



SSAT Project 13 – Condensate Return Savings

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 5


Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	6,132	0	0.0%
Fuel Cost	55,289	55,206	83	0.1%
Make-Up Water Cost	1,086	1,042	44	4.0%
Total Cost (in \$ '000s/yr)	62,507	62,380	126	0.2%

On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	221739 t/yr	221408 t/yr	332 t/yr	0.1%
SOx Emissions	0 t/yr	0 t/yr	0 t/yr	N/A
NOx Emissions	439 t/yr	438 t/yr	1 t/yr	0.1%

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	2000 kW	-	-
Power Import	5000 kW	5000 kW	0 kW	0.0%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	140552 kW	211 kW	0.1%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12604.2 Nm3/h	18.9 Nm3/h	0.1%
Boiler Steam Flow	150.1 t/h	149.9 t/h	0.2 t/h	0.1%
Fuel Cost (in \$/MWh)	44.84	44.84	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m3/h	70 m3/h	3 m3/h	4.0%

Cascade Condensate Systems



Source: US DOE ITP Steam BestPractices Program

SSAT Projects 14 & 15 - Condensate Flash Tanks

Project 14 - Condensate Flash to MP

Not currently installed

Do you wish to modify the MP condensate flash system?


Yes, install condensate flash to MP

Project 15 - Condensate Flash to LP


Not currently installed

Do you wish to modify the LP condensate flash system?

Yes, install condensate flash to LP



SSAT Projects 14 & 15 – Condensate Flash Tanks



SSAT Project 14 & 15 – Condensate Flash Tanks

Results Summary

SSAT Default 3 Header Metric Model Moldova Ex 7

Model Status : OK

Cost Summary (\$ '000s/yr)	Current Operation	After Projects	Reduction	
Power Cost	6,132	6,132	0	0.0%
Fuel Cost	55,289	54,024	1,265	2.3%
Make-Up Water Cost	1,086	1,087	-2	-0.1%
Total Cost (in \$ '000s/yr)	62,507	61,243	1,264	2.0%

On-Site Emissions	Current Operation	After Projects	Reduction	
CO2 Emissions	221739 t/yr	216665 t/yr	5075 t/yr	2.3%
SOx Emissions	0 t/yr	0 t/yr	0 t/yr	N/A
NOx Emissions	439 t/yr	429 t/yr	10 t/yr	2.3%

Utility Balance	Current Operation	After Projects	Reduction	
Power Generation	2000 kW	2000 kW	-	-
Power Import	5000 kW	5000 kW	0 kW	0.0%
Total Site Electrical Demand	7000 kW	7000 kW	-	-
Boiler Duty	140763 kW	137542 kW	3221 kW	2.3%
Fuel Type	Natural Gas	Natural Gas	-	-
Fuel Consumption	12623.1 Nm3/h	12334.2 Nm3/h	288.9 Nm3/h	2.3%
Boiler Steam Flow	150.1 t/h	146.7 t/h	3.4 t/h	2.3%
Fuel Cost (in \$/MWh)	44.84	44.84	-	-
Power Cost (as \$/MWh)	140.00	140.00	-	-
Make-Up Water Flow	73 m3/h	73 m3/h	0 m3/h	-0.1%


SSAT Project 11 – Condensate Tank Vent HX

Project 11 - Feedwater Heat Recovery Exchanger using Condensate Tank Vent
Not currently installed

Modify the condensate tank vent heat recovery system?

No

Note: An approach temperature of 10°C will be assumed for a new exchanger



Condensate return
Temperature should
be > 100°C

✓ Note that this Project is possible ONLY with condensate return temperatures > 100°C



Key Points / Action Items

1. *Returning condensate*
 - *Reduces energy*
 - *Reduces make-up water*
 - *Reduces chemicals for water treatment*
 - *Reduces quenching water*
 - *May reduce blowdown*

2. *Condensate recovery is often neglected but it can provide significant energy savings*

3. *Quantify the amount of condensate being recovered in a plant using a simple mass balance on the entire steam system*

4. *Identify potential areas of condensate recovery*



Common BestPractices - Recovery

- ✓ Implement an effective steam-trap management and maintenance program
- ✓ Recover as much as possible of available condensate
- ✓ Recover condensate at the highest possible thermal energy
- ✓ Flash high-pressure condensate to make low-pressure steam